

1
THIRD ANGLE PROJECTION



2
DO NOT SCALE

3
DIMENSIONS IN mm

GLANDING OPTIONS	GLANDING DESCRIPTION	ACCEPTABLE TYPES
A20	FOR SW ARMoured CABLE, NICKEL PLATED BRASS, M20, Ex d/e, DOUBLE SEAL GLAND	CAPRI No. 846694 CMP No. 205/E1FW ELECTRO N.P BRASS CMP No. 205/T3/CDS ELECTRO N.P BRASS HAWKE No. 501/453/UNIV/O/M20/AR FULL NICKEL PLATED BRASS
R20	FOR SW ARMoured CABLE, STAINLESS STEEL, M20, Ex d/e, DOUBLE SEAL GLAND	CAPRI No. 846699 CMP No. 205/E1FW STAINLESS STEEL CMP No. 205/T3/CDS STAINLESS STEEL HAWKE No. 501/453/UNIV/O/M20/AR STAINLESS STEEL
C20	FOR UNARMoured CABLE, N.P BRASS, M20, Exe, SINGLE SEAL GLAND	CMP No. 205A2F N.P BRASS PEPPERS No. A3LF NP/20s/M20 CAPRI No. 816694
P20	FOR UNARMoured CABLE, PLASTIC, M20, Exe, SINGLE SEAL GLAND	CROUSE-HINDS No. GHG 960 9235 P 0203 JACOB GmbH No. 50.620 PASWL/EX
S20	FOR UNARMoured CABLE, STAINLESS STEEL, M20, Ex e, SINGLE SEAL GLAND	CAPRI No. 816699 CMP No. 205A2F STAINLESS STEEL PEPPERS No. A3SLF /20s/M20
O20	M20 CLEARANCE HOLE ONLY	QTY = MAX No. OF SPURS +1 + BREATHER
X20	M20 NICKEL PLATED BRASS, Ex e PLUG	QTY FITTED = MAX No. OF SPURS +1
Y20	M20 PLASTIC, Ex e PLUG	QTY FITTED = MAX No. OF SPURS +1

NOTE
TABLE ABOVE SHOWS APPROVED GLANDING DETAILS FOR THE FOLLOWING DESIGN RULE DRAWINGS,
AD9033-001, AD9034-001, AD9035-001, AD9036-001, AD9037-001, AD9038-001 & AD9039-001

Sht. 1 of 1

1	10.04		Scale N/A	Copyright Reserved Written Permission To Copy Should Be Obtained	Measurement Technology Ltd Power Court, Luton, England		Title APPROVED GLANDING LIST FOR FIELDBUS JB'S	Drg. No	Iss.
Iss	Date	Modification	Tolerance N/A					AD9030-001	1

S-EDGE 1 2 3 4 5 6 7 8 A3